

Vidyasagar Central Co-operative  
Bank Ltd., Midnapore FAX - 03222 -  
Head office: - Midnapore  
At & P.O. - Midnapore,  
Dist. - PaschimMedinipur



Telephone – 03222–275417, 275411  
275411  
E-mail – vccbmidnapore@gmail.com

Memo- Dev /192Date- 27/09/2018

## **Notice Inviting Quotation**

**E-Tender No. VCCBL/Memo/Dev/192 /2018-19/ET-023**

**Notice inviting quotations for supplying and fixing of necessary Electrical materials for installation all electrical points and A.C. points at Newly constructed Building of Mohanpur Branch of Vidyasagar CCB Ltd.**

**Sealed item rate quotations are hereby invited from reputed & experienced person /Supplier/Vendor.**

**Name of work: - Esteemed Supplier/Vendor to Supplying and fixing of necessary electrical materials for fixing and installation of Electrical Points and A.C. points** at Newly constructed Mohanpur Branch of Vidyasagar CCB Ltd. At Mohanpur, PO :Mohanpur, Dist : PaschimMedinipur.

*Location & Place: Mohanpur Branch*

*Last date & time of submission of Quotation:- 12/10/2018 up to 12 noon*

*Date & time of Opening of Quotation:- 12/10/2018 at 4 pm*

website: [www.vidyasagarccb.in](http://www.vidyasagarccb.in) or VCCBL e-tender portal [www.tenderwizard.com/eproc](http://www.tenderwizard.com/eproc)

### **Help Desk:**

Contact Person: Mr.Kushal Bose / Mr.TousikGhosh

Mobile no. 07686913157 / 09674758724 (On working days-9 hours–18 hours)

e-mail:[kushal.b@antaressystems.com](mailto:kushal.b@antaressystems.com) / [tousik.g@antaressystems.com](mailto:tousik.g@antaressystems.com)

**Terms & condition:** *Supporting documents should be submitted against qualification of bid and also will have to be submitted PT, Trade license, PAN CARD, GST Registration certificate, IT Return.*

- A.** All bid must be accompanied by a refundable earnest money / bid security amount of Rs.10000/- to the A/C No :123005627958 (IFSC Code: WBSC0VCCB39)Vidyasagar Central Co- Operative Bank Ltd., Midnapore.
- B. Tender Fees Of Rs.200 (Non Refundable)**
- C.** The quotation should indicate specifically the basic price ,taxes, other duties if any no additional information will be entertained after due date.
- D.** No revision of rates shall be allowed except taxes / charges levied by the Central / State by dully notified only.
- E.** No advance or running payment shall be made. Payment shall be released after the satisfactory supply.

- F.** The undersigned is the accepting authority who reserves the right to reject any or all quotations without assigning any reason and any notice or he will not bound to accept either the lowest tender at any of the bidders.
  
- G.** Maintenance period shall be one year from the date of successfully completion of work. During this period you will be liable for any defect in the work due to bad workmanship and all the defects shall be rectified by your own cost immediately. If you fail to rectify / remove the defects within 7 (Seven) days from the time of its reporting, the bank will have the option to take assistance from any third party to solve the said defects. In that event, the entire cost for this repairing will have to be borne by you.
  
- H.** The Bank will have the liberty to deduct requisite amount of TDS from your bill amount for onward remittance to the concerned office in the Government.
  
- I.** Safety & Security measures are to be taken by the contractor solely . Bank will not be responsible for any kind of mishap during the aforesaid construction works.
  
- J.** Completion Certificate from the concerned Branch Officials/Manager have to be submitted at the time of submission of the final bill.
  
- K.** Bank's GST No- 19AAAV0691B1Z00 and Company's GST No must be quoted in Tax Invoice Bill.

**For further details please visit our website [www.vidyasagarccb.in](http://www.vidyasagarccb.in) or contact P& D Section , H.O. Midnapore or see notice Board of the Bank .**

**Date:-27/09/2018  
General Manager**



TENDER NO.VCCBL/Memo/Dev/192 /2018-19/ET-023

DATED: 27/09/2018

Tender Description : Electrical installation work for newly constructed building at Mohonpur Branch of Vidyasagar Central Co. Op. Bank Ltd.

**PRICE BID**

Name of Firm / Contractor / Vendor:

Postal Address:

Mobile No.

E-Mail ID:

PAN No.

GST No.

SI. No.	DESCRIPTION OF WORKS	Qty.	Unit	Rate (Rs.)	Total Rate (Rs.)	In Words (Rs.)
1	Supplying & laying 4 core 50 sqmm. PVC Armoured Aluminium cable on wall / Surface incl. S & F M.S. Saddles making holes etc. as necessary mending good damages & painting.	10	Mtr.		0.00	
2	Supplying and fixing 415V,125A. TPN SFU with sheet steel enclosure on flat iron/angle iron frame on wall with nuts bolts etc incl. S & F 3 nos. DIN type HRC fuse as per rating. (L & T make)	1	Each		0.00	
3	Supplying & fixing 3 (three) nos. 125 Amp. SFU with rewirable type fuse unit [i.e. base & bridge] & neutral link on 12" x 10" bakelite board.	1	Item		0.00	
4	Supplying and fixing 415V, 125A. TPN on load front operated changeover switch with Sheet Steel enclosure on angle iron frame on wall with nuts bolts etc (L & T make)	1	Each		0.00	
5	Cable end finishing for 4 core 50 sqmm. Al. cable	6	Sets		0.00	
6	a) Supplying and fixing double door Horizontal TPN MCB Distribution board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment, Legrand 6 way	1	Each		0.00	
	b) Supplying and fixing double door Horizontal SPN MCB Distribution board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment, Legrand 2+12 way.	2	Each		0.00	
	c) Supplying and fixing double door Horizontal SPN MCB Distribution board with IP-42/43 protection, concealed in wall after cutting the wall & mending good the damages to original finish incl. Inter connection with suitable size of copper wire and neutral link & provision for earthing attachment, Legrand 2+8 way.	1	Each		0.00	
7	Supplying and fixing 240/415 V 100A FP. MCB Isolator on din rail of existing DBs and necessary connection. Legrand	1	Each		0.00	
8	Supplying and fixing 240 V, 6 - 32 Amp. MCB of Breaking capacity 10kA & C characteristics on din rail of existing DBs and necessary connection, Legrand	52	Each		0.00	

9	Supplying and fixing 240 V 40A DP. MCB Isolator on din rail of existing DBs and necessary connection. Legrand	5	Each		0.00	
10	Supplying and fixing MCB SS enclosure with IP-20/30 protection, powder coated provision for two/four pole MCB, concealed in wall after cutting the wall & mending good the damages to original finish incl. painting, connection & provision for earthing attachment (4way)	2	Each		0.00	
11	Proriding & correction of sheet metal (16SWG) iron clad busbar chamber on angle iron frame on wall in corporate with 4 bary 415V, 200A, 4x20x5 mm cu bar, (0-50A) Range ammeter, (0-500V) Voltmeter, 3 nos indicating lamp, (LED type), 1no danger board, inter connection as per required.	1	Item		0.00	
12	Distribution wiring in 2 x 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in 20mm size PVC rigid conduit 'FR' (Precision make), with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, to light/fan/call bell points with Modular type switch (Brand approved by EIC) fixed on Modular GI switch board with top cover plate and 2 no. suitable size "Ph & N" copper bar & earthing attachment fixed on wall incl. mending good damages to original finish. Average run 8 mtr.	95	pt.		0.00	
13	Distribution wiring in 1.1 KV grade 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in 20mm size PVC rigid conduit 'FR' (Precision make), with 1.1 KV grade 1 x 22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire as ECC, to 6A 3 pin Modular type plug socket & switch (Brand approved by EIC) on 4 Module GI switch board with 3/4 Module top cover plate on wall incl. necy. connection making earthing attachment, painting and mending good damages to building works. On Board.	9	pt.		0.00	
14	a) Supply & Fixing 240 V, 6 A, 3 pin Modular type plug socket (Brand approved by EIC) with 6A Modular type switch, without plug top on 4 Module GI Modular type switch board with 3 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	3	Each		0.00	
	b) Supply & Fixing 240 V, 16 A, 3 pin Modular type plug socket (Brand approved by EIC) with 16A Modular type switch, without plug top on 4 Module GI Modular type switch board with top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	5	Each		0.00	
	c) Supply & Fixing 240 V, 4 nos. 6 A, 3 pin Modular type plug socket with 4 nos. 6A Modular type switch (Brand approved by EIC), 16A Modular switch type MCB (C-Curve) and Indicator without plug top on 2 row 18 Module GI Modular type switch board with 2 row 18 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	7	Each		0.00	
15	Supply & Fixing 240V, Modular Socket (2 Module) type fan regulator (Step type) (Brand approved by EIC) on existing Modular GI switch board with top cover plate incl. making necy. connections etc.	5	Each		0.00	
16	a) Supply & Fixing 240 V, 25 A, Modular type starter (Brand approved by EIC) with 25A Modular switch type DP MCB (C-Curve) and 4 Module GI Modular type switch board with 4 Module top cover plate flushed in wall incl. S&F switch board and cover plate and making necy. connections with PVC Cu wire and earth continuity wire etc.	7	Each		0.00	

	b) Supply & Fixing 240 V, 25 A, 3 pin Modular type plug socket (Brand approved by EIC), without plug top and switch with 2 Module GI Modular type switch board with top cover plate flushed in wall and making necy. connections with PVC Cu wire and earth continuity wire etc.	7	Each		0.00	
17	Supplying and fixing PVC Rigid Conduit 'FR' [Precision Make] on wall, ceiling with saddles and other accessories as required and mending good damages to building works 20mm size	250	Mtr.		0.00	
18	a)Supplying and Drawing 3 x 36/0.3 (2.5 sqmm) 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required	9	R.M		0.00	
	b)Supplying and Drawing 4 x 80/0.4 (10 sqmm) 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required	12	R.M		0.00	
	c)Supplying and Drawing 2x84/0.3 (6 sqmm) + 1x56/0.3 (4 sqmm) as ECC 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required	40	R.M		0.00	
	d)Supplying and Drawing 2x36/0.3 (2.5 sqmm) + 1x22/0.3 (1.5 sqmm) as ECC 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required	110	R.M		0.00	
	e)Supplying and Drawing 2x56/0.3 (4 sqmm) + 1x36/0.3 (2.5 sqmm) as ECC 1.1 KV single core stranded 'FR' PVC insulated & unsheathed single core stranded copper wire (Brand approved by EIC) of the following sizes in the prelaid polythene pipe and by the prelaid GI fish wire and making necy. connection as required	175	R.M		0.00	
19	Supply & fixing angular batten holder on 75mm dia round bakelite on wall/ceiling incl. 230V 12W LED lamp (Havells).	10	Each		0.00	
20	Supplying & fixing 4' single Fluorescent light fittings (Havells make) directly on wall with suitable size bullet fastner, ball socket, nipple etc.	5	Each		0.00	
21	Supplying & fixing 230V. 50Hz 48" A.C ceiling fan complete down rods canopy, fork blades rubber bush etc. (Make C.G high speed), incl. making connection as required.	5	Each		0.00	
22	Supplying & fixing special decorative type 230V. 15W circular LED light fittings (Philips make).	54	Each		0.00	

23	Earthing with Copper plate (610x610x3mm size) having weight of 9.84 Kg and 1 No. 25x5mm Copper strip (3.20 mt long) & 1 no. 6 sqmm PVC insulated stranded Copper wire (4 Mt long) incl. S & F 15 mm dia GI pipe (ISI-Medium) protection (4 mt. long) to be filled with bitumen, partly under the ground level & partly above ground level to an average depth of 3.65 Mts. below the ground level and restoring the surface duly rammed incl. providing 3.0 mt long, 25 mm dia GI pipe (ISI-Medium) for periodic treatment, incl. providing masonry enclosure on the top of the earth electrode of overall size 86.36x86.36x46cm deep (below Ground level) complete with cemented brick work(1:6) of 25 cm width, duly plastered with cement mortar(inside) CI hinged inspection cover of size 36.56x35.56cmwith locking arrangement, GI reducer and treatment of soil by using salt & charcoal or coke for plate electrode	2	Each		0.00	
24	Connecting the equipments to earth busbar including S&F copper strip of size 25x5mm in U.G trench with necy. Arrangement.	30	Mtr.		0.00	
25	Supply & fixing 230V 9" A.C exhaust fan (heavy duty type) Havells make.	3	Each		0.00	
26	Supply & fixing 400mm sweep wall mounted fan (Havells make) High Speed type.	16	Each		0.00	
27	Supply & fixing 50mm x 6mm Extra Busbar including Porcelain insulator.	0.5	Mtr.		0.00	
28	Supply & Fixing RJ45 sitable for CAT6 cable (Brand approved by EIC) with PVC board and top cover plate on wall and making necessary connections & testing as required	7	Each		0.00	
29	Supplying & Drawing LAN cable (CAT6) (Brand approved by EIC) in prelaid PVC rigid conduit/ in polythene pipe embeded in wall.	105	Mtr.		0.00	
30	Supplying and fixing PVC Rigid Conduit 'FR' [Precision Make] on wall, ceiling with saddles and other accessories as required and mending good damages to building works 20mm size.	105	Mtr.		0.00	
	<b>TOTAL</b>				<b>0.00</b>	